

Government of Andhra Pradesh**A.P. State Disaster Response and Fire Services Department****Periodical Renewal Fire Certificate**

From:
Regional Fire Officer
Zone-2,Rajahmundry
Andhra Pradesh.

To:
District Educational Officer,

File No: 31447/KRI/RFO/2026, Date:28/04/2026

Occupancy NoC RC Number: 286/RFO/ER/2017, Dt : 03-03-2017

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **V.S.St.Johns High School, represented by Brother Santhosh, D.No.3-85/1 , R.S.No.419/P,437/P,438/3,441/P,444/Pand 445/P, Buddavaram (V) , Gannavaram (M) , Krishna District.** - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. 286/RFO/ER/2017 , Dt : 03-03-2017, Dt.01/01/1900
 4. Renewal NOC For Occupancy 286/RFO/ER/2017 , Dt : 03-03-2017, Dt.01/01/1900
 5. Online Application for Renewal NOC of Brother Santhosh, D.No.3-85/1 , R.S.No.419/P,437/P,438/3,441/P,444/Pand 445/P, Buddavaram (V) , Gannavaram (M) , Krishna District. - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 24-04-2026.

-- x --

The Management of V.S.St.Johns High School, represented by Brother Santhosh, D.No.3-85/1 , R.S.No.419/P,437/P,438/3,441/P,444/Pand 445/P, Buddavaram (V) , Gannavaram (M) , Krishna District. has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.84976/- vide challan No. 11012032202026, Dated 17/04/2026 at SBI, Gannavaram.

Block - I ,Auditorium ,Block - V ,Block - III

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **Brother Santhosh D.No.3-85/1 , R.S.No.419/P,437/P,438/3,441/P,444/Pand 445/P, Buddavaram (V) , Gannavaram (M) , Krishna District.**, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.

2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 23/03/2026 to 22/03/2028.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
11012032202026	2026-04-17	84976

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

The inspection committee DDRF0-Krishna and FSI0-Gannavaram has offered the remarks as Recommended : Namaskaram Sir, We have inspected the premises of V.S. St. John's High School, located at D.No. 3-85/1, R.S.No. 419/P, 437/P, 438/3, 441/P, 444/P, and 445/P, Buddavaram Village, Gannavaram Mandal, Krishna District on 24-04-2026. During the inspection, it was observed that all blocks are being utilized for educational occupancy. (1).The management has previously obtained a No Objection Certificate (NOC) for occupancy vide Rc.No. 286/RF0/ER/2017, dated 03-03-2017, and has been regularly obtaining the Annual Fire Safety Certificate every year. (2).As per the conditions of the NOC, all required firefighting equipment has been provided and was found to be in good working condition at the time of inspection. (3).Further, the management has paid a challan amount of Rs. 84,980/- towards the Fire Precautionary Fee for the issuance of the Annual Fire Safety Certificate for a period of two (02) years. (4).When I informed the school principal about the payment of the Basic Fire Fighting Training fee, he communicated the matter to the higher authorities and assured that the payment would be made shortly. Hence, Recommended for Issue of Annual Fire Safety Certificate for Occupancy.

"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"**"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"****"సురక్షిత పాఠశాలలు, సురక్షిత మైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రత పై స్పృహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."**

Your Sincerely,

[Handwritten Signature]
 28/4/26
 Regional Fire Officer
 Zone-2, Rajahmundry
 Andhra Pradesh.

In case of emergency, please call 101 or 08676-252401 or 9963724938

Copy to Brother Santhosh, Santhosh Brother ,V.S.St.Johns High School , Gannavaram

Copy to Chief Office for Record Purpose

Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned