

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No

Dated:

It is certified that an inspection team headed by Sri V. Rajarao Senior Water Analyst

(Name of Officers with designation) from Regional Public Health Laboratory, Guntur

inspected the V.S. St. John's Higher Secondary School, Gennavaram

(Name & Address of the school) on 21/4/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 2762, 2763 dated 21/4/2026

of Regional Public Health Laboratory (PHED Lab) certified that

the V.S. St. John's Higher Secondary School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till One year

Signature with Seal:

Name

Designation

Name & Address of the Office / Department

To V.S. St. John's Higher Secondary School

Gennavaram, Krishna District

(Name & Address of the Institution) 521101. A.P.

Regional Public Health Laboratory
Senior Analyst Water AP
Regional Laboratory
Medical College Campus
Guntur-4

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



GOVERNMENT OF ANDHRA PRADESH
DIRECTORATE OF I.P.M.PH.LABS, FOOD (H) ADMN, Mangalagiri, Guntur.
REGIONAL PUBLIC HEALTH LABORATORY, GUNTUR

REPORT OF PHYSICO CHEMICAL ANALYSIS OF WATER

Sample from	V.S.St.John's Higher Secondary School, St.John's Nager, Gannavaram, Krishna Dt, Pin: 521101, A.P.	Lab. Ref. No:	2762
		Collected on	21.04.2026
		Received on	21.04.2026
Collected by	Staff.	Source Profile	Ro Water

		Source / Sample	Limits as per IS 10500:2012	
		Drinking water tap Ro treated at above address.		
S. No	Parameter		Desirable (Acceptable limit)	Permissib le limit in the absence of alternativ e source
Physical Parameters				
1	Colour (Hazen units)	≤5.0	5	15
2	Turbidity in NTUS''	0.1	1	5
3	Odour	Unobjectionable	Unobjectionable	Agreeabl e
4	pH	6.9	6.5 – 8.5	No relaxation
5	Conductivity at 25 °C (Micro Mhos/ Cm)	100	...	
6	TDS (mg/L)	66	500	2,000
Chemical parameters (mg/L)				
1	Alkalinity (as CaCO ₃)	Nil	...	
2	Total Alkalinity. Max	20	200	600
3	Total hardness max	24	300	600
4	Calcium hardness (as CaCO ₃)	12	..	
5	Magnesium hardness (as CaCO ₃)	12	..	
6	Calcium (as Ca)	5.0	75	200
7	Magnesium (as Mg)	3.0	30	100
8	Ammonical Nitrogen	Nil	...	
9	Nitrite (as N)	Nil	...	
10	Chloride (as Cl)	20	250	1,000
11	Fluoride (as F)	0.1	1	1.5
12	Iron (as Fe)	Nil	0.3	No relaxation

Remarks: The given sample physico chemically Satisfactory for drinking purpose as the analysed parameters are within the desirable limits.



R. J. M. S.
25/4
Senior Analyst (Water)
Regional Laboratory
Medical College Campus
Guntur - 4

GOVERNMENT OF ANDHRA PRADESH
DIRECTORATE OF I.P.M., P.H.LABS, FOOD (H), ADMINISTRATION, Mangalagiri, Guntur.
REGIONAL P.H.LABORATORY, MEDICAL COLLEGE CAMPUS, GUNTUR -4
REPORT OF MICROBIOLOGICAL ANALYSIS OF WATER

Sample(s) from: V.S.St.John's Higher Secondary School, St.John's Nager, Gannavaram,
Krishna Dt, Pin: 521101, A.P.

Collected on: 21.04.2026

Received on : 21.04.2026

Paid / Free : Paid

Collected by : Staff.

S.No	Lab Ref. No	SOURCE	Residual Chlorine mg.per litre	MPN of Coliform Bacteria Per 100 ml.	Nature of Coliform Bacteria Isolated	MPN of Esch. coli.
1	2763	Tap water Ro Treated at above address.	Nil	Nil	-	-

Remarks:- The given sample is bacteriologically satisfactory for drinking purpose as evidenced by the Nil MPN count of coliform bacteria.



R. P. M. W.
25/4
Senior Analyst (Water)
Regional Laboratory
Medical College Campus
Guntur - 4